

IFIC FLARE



IFIC Forensics is alerting insurers and loss adjusters to recent recall notices related to products which could cause electrical shock, burns, fire or other risk

Hager 10Ka MCB 5/10/16

Hager have recalled a 'Hager 10Ka MCB' in which a non-conformity has been identified. This non-conformity could affect how the MCB functions. These MCB's were produced between 7th of July 2016 and 6th of October 2016.

Hager are advising that use of these MCB's should be stopped with immediate effect and all distribution boards should be checked for any product references as shown on their web site here.



[For further information click here](#)

Terasaki Miniature Circuit Breakers 25/10/16

The TD3 M10 and TD3 M06 models of the MCB have been identified as having a 'raw material non-conformity' in certain batches, which could cause the product to fail, potentially placing users at risk.

Users are advised to stop using immediately.

[For further information click here](#)

European Commission Rapid Alerts System

The European Commission Rapid Alerts System for non-food products has published their weekly report (48) identifying a series of Christmas Light and other products that pose a serious risk from fire.

Please follow the links below for further detail:

[Alert A12/1573/16 Christmas Lights](#)

[Alert A12/1574/16 Christmas Lights](#)

[Alert A12/1561/16 Drift Trike \(Electric Bike\)](#)

